



Town of Truckee
Water Efficiency and Conservation
Compliance Documentation

WORKSHEET (WS-1) (Duplicated from 2010 CGBC) BASELINE WATER USE									
FIXTURE TYPE	FLOW RATE (gpm) ²		DURATION		DAILY USES		OCCUPANTS ^{3,4}		GALLONS PER DAY
Showerheads	2.5	X	5 min.	1	1	X		=	
Showerheads residential	2.5	X	8 min.	X	1	X		=	
Lavatory faucets residential	2.2	X	.25 min.	X	3	X		=	
Lavatory faucets nonresidential	0.5	X	.25		3	X		=	
Kitchen faucets	2.2	X	4 min.	X	1	X		=	
Replacement aerators	2.2	X		X		X		=	
Wash fountains	2.2	X		X		X		=	
Metering faucets	0.25	X	.25 min.	X	3	X		=	
Metering faucets for wash fountains	2.2	X	.25 min.	X		X		=	
Gravity tank type water closets	1.6	C	1 flush	X	1 male ¹ 3 female	X		=	
Flushometer tank water closets	1.6	X	1 flush	X	1 male ¹ 3 female	X		=	
Flushometer valve water closets	1.6	X	1 flush	X	1 male ¹ 3 female	X		=	
Electromechanical hydraulic water closets	1.6	X	1 flush	X	1 male ¹ 3 female	X		=	
Urinals	1.0	X	1 flush	X	2 male	X		=	
Total daily baseline water use (BWU)								=	
_____ (BWU) x .8 = _____ Allowable water use									

1. The daily use number shall be increased to three if urinals are not installed in the room.
2. The flow rate is from the CEC Appliance Efficiency Standards, Title 20 California Code of Regulations; where a conflict occurs, the CEC standards shall apply.
3. For low-rise residential occupancies, the number of occupants shall be based on two persons for the first bedroom, plus one additional person for each additional bedroom.
4. For nonresidential occupancies, refer to Table A, Chapter 4, 2010 California Plumbing Code, for occupant load factors.