



Class B Shingles for Exterior Siding

PURPOSE: To approve the use of Class B fire retardant treated wood shingles and shakes for exterior wall covering material.

COMMENTS:

Amendments by State agencies of the upcoming 2022 California Building and Residential Codes are now available on the Building Standards Commission website. Section R337.4.4 of the 2022 California Residential Code defines Class B fire retardant treated wood shingles and shakes as defined in Section 1505.6 of the California Building Code and listed by State Fire Marshal for use as Class B roof covering, as an ignition resistant wall covering material when installed over solid sheathing.

Based on the State Fire Marshal's approval, Class B fire retardant treated shingles and shakes installed over solid sheathing are approved for use in Truckee as an ignition resistant wall covering material.